

Brazil



EPIC Deploy: Brazil Cooling assessment¹



¹ **Scope and use:** This report provides contextual and screening-level information to support the preparation of applications. It is not a technical design standard, legal opinion, official national inventory or substitute for site-specific due diligence. Applicants remain responsible for validating demand, baseline conditions, equipment sizing, regulatory compliance and expected emission reductions for the proposed project.



Cooling Demand Taxonomy

Brazil is one of the world's most complex cooling markets. It combines one of the cleanest electricity systems globally with rapidly increasing cooling demand, a large domestic RAC manufacturing base and one of the highest populations exposed to cooling poverty in Latin America. The principal country framework conditions are summarised in Table 1 for quick reference, and each dimension is developed in the sections that follow.

Table 1 – Brazil: key cooling taxonomy data

Economics and Demographics		Climatic conditions	
GDP (2024)	approx. USD 2,200 B [1]	National avg. Cooling Degree Days (18°C base)	2,901 °C·day/yr [2]
GDP per capita	approx. USD 10,300 [1]	Range of biome average temperatures	≈ 16–29 °C [3]
GDP growth rate (medium-term)	3.4%/yr [1]	Additional hot days per year increase by mid/late century	+133 to +327 days (SSP2-4.5) [4]
Total population (2024)	approx. 212.6 M [5]	Hot days projected by mid-century	up to 45% of days/yr [4]
Population growth rate	0.5%/yr [5]	Projected warming by 2050s	+1.2 to +2.2 °C [6]
Urban population share	approx. 87% [7]	Growth in residential cooling CO ₂ emissions under +4 °C warming	+190% vs today [8]
Urban growth rate	≈ 0.9%/yr [7]		
Population in favelas / comunidades	16.4 M (8.1%) [9]		
Growth-driving sectors	Services, agribusiness, industry [1]		
Energy infrastructure		Regulatory framework	
National electrification rate	100.0% (rural 97.3%) [10]	MEPS for cooling appliances	In force (IDRS; Res. 1/2022) [11]
Total electricity production	751.3 TWh generated in 2024 [12]	HCFC consumption phase-out target	2030 [13]
Hydropower share of supply	56.1% [12]	HFC phase-down (Kigali Amendment)	Decreto 11.666/2023 [14]
Renewable share of generation	88.3% [12]	National Cooling Action Plan	Drafting started Mar 2026 [15]
Grid reliability	10.24 h/yr; 4.89 interruptions/yr [16]	NDC emissions reduction target	–59 to –67% by 2035 vs 2005 [17]
Residential electricity tariff	Varies by distribution area; verify current B1 tariff in ANEEL database [18]	Import conformity requirement	INMETRO conformity assessment and ENCE labeling, where the product is regulated [19]
Grid emission factor	0.0599 kgCO ₂ eq/kWh [20]	Energy efficiency regulation	Lei 10.295/2001; PBE/PROCEL [19]

The electricity-generation total and mix are based on IEA 2024 data [12], while the grid emission factor and service-continuity metrics are supported by EPE and ANEEL sources [16][20][21]. Brazil generated 751.3 TWh of electricity in 2024 [12], while final electricity consumption was 650.4 TWh [20]. Sector shares in this report



are therefore compared with final electricity consumption. The screening-level grid emission factor used throughout the chapter is 59.9 kg CO₂e/MWh (BEN 2025, base year 2024) [20].

General Overview

Geography and climate

Brazil extends across almost half of South America and encompasses six terrestrial biomes that differ sharply in temperature, humidity and population density, producing correspondingly different cooling needs. The country's climatic heterogeneity is governed chiefly by latitude and continentality: an equatorial, humid north in Amazônia; a hot, semi-arid interior in the north-east within the Caatinga; an extensive tropical savanna in the Cerrado; and a more temperate, densely populated south and south-east spanning the Mata Atlântica and Pampa. The biome breakdown in Table 2 and the map in Figure 1 provide a reference framework used throughout the assessment.




Figure 1 – Brazil: geography and climate



Table 2 – Brazil: climatic zones general data

Biome	Area share [22]	Average temperature [3]	Climate	Key cooling relevance
Amazônia	49.5%	≈ 26–28 °C	Equatorial, hot-humid, high RH	High latent loads; isolated and off-grid systems in the North; humidity-driven discomfort
Cerrado	23.3%	≈ 22–26 °C	Tropical savanna, marked dry season	High sensible cooling demand; agribusiness and cold-chain heartland
Mata Atlântica	13.0%	≈ 18–24 °C	Tropical to subtropical	Largest population and cooling market (SP, RJ, MG, South); urban heat islands
Caatinga	10.1%	≈ 26–29 °C	Semi-arid, highest ambient temperatures	Highest per-capita thermal stress; lower incomes; concentrated vulnerability
Pampa	2.3%	≈ 16–20 °C	Subtropical, seasonal	Lower cooling demand; heating also relevant
Pantanal	1.8%	≈ 24–27 °C	Tropical wetland, hot	Sparse population; niche demand

Climate projections raise cooling requirements across every biome. Under intermediate and high-emissions scenarios, mean temperatures are projected to rise by between 1.2 °C and 2.2 °C by mid-century [6], with larger increases in the continental interior towards the end of the century. The number of hot days rises steeply: projections indicate between 133 and 327 additional hot days per year (TX90p) under SSP2-4.5, and up to 234 to 328 under SSP5-8.5 by 2100, with effects concentrated in the North and North-East and on vulnerable populations [4]. According to a Brazil-specific study of the residential sector space-cooling CO₂ emissions could increase by roughly 70% at 1.5 °C of warming and by as much as 190% at 4 °C relative to today [8]. Cooling demand is therefore both large in absolute terms and rising rapidly.

The national average Cooling Degree Days on an 18 °C base, calculated from the World Bank Climate Change Knowledge Portal, is about 2,901 [2]. A visual representation of the spatial distribution of this indicator is provided in Figure 2.




Figure 2 – Brazil: cooling degree days 18°C spatial distribution

Population, Urbanisation and Vulnerability

Brazil is already highly urbanised, with roughly 87% of the population living in cities [7]. The dominant cooling-relevant dynamic is therefore not rapid urban in-migration but the thermal vulnerability of dense, established urban settlement, set against an ageing and slow-growing population whose annual growth is close to 0.5% [5]. Key demographic and vulnerability indicators are reported in Table 3.

Table 3 – Brazil: general demographic data

Indicator	Value
Total Population (2024)	212.6 M [5]
Population growth rate	0.5%/yr [5]
Urban population share	approx. 87% [7]
Population in favelas / comunidades urbanas	16,390,815 (8.1%) [9]
Number of favelas / comunidades urbanas	12,348 [9]
States with highest favela share	Amazonas 34.7%, Amapá 24.4%, Pará 18.8% [9]
Most populous favela	Rocinha, RJ (72,021) [9]




Figure 3 – Brazil: population density



Brazil's population is highly concentrated, with most urban areas clustered along the Atlantic coast and in the Southeast, a region that alone accounts for roughly 42% of the population on just 11% of the national territory, while the vast Amazonian interior remains sparsely settled [7].

Building Stock and Thermal Exposure

In Brazil's dense urban centres the built environment is a primary determinant of heat risk. Favelas and comunidades urbanas, home to 16.4 million people [9], combine lightweight and poorly insulated construction with high density and limited vegetation, which amplifies indoor overheating during heat waves. Urban heat-island intensity in the largest metropolitan areas is material: in the Rio de Janeiro metropolitan region, more than 60% of municipal schools stand in heat-island zones where mean annual temperatures exceed 32 °C [23].

Construction practice compounds the exposure. Much of the lower-cost housing and public building stock relies on fibre-cement or thin concrete roofing with little thermal mass and minimal shading, so internal temperatures track outdoor peaks closely [24]. Passive measures such as reflective coatings, roof insulation, cross-ventilation and shading therefore carry significant potential, particularly in the hot interior and the North-East, where their cost is modest relative to mechanical cooling.

Economy and Energy Poverty

In Brazil the binding constraints on cooling are affordability and equity rather than an absolute lack of grid access. Near-universal electrification, at close to 100% nationally and 97.3% in rural areas [10], coexists with rising real electricity tariffs and with access gaps that fall on lower-income, informally housed and rural-poor households. SEforALL classifies 34.2 million Brazilians as at high risk from a lack of access to cooling, the largest such population in Latin America and the Caribbean, of whom about 4.3 million are rural poor [25]. Indicators relevant to cooling market potential and to financing are reported in Table 4.

Table 4 – Brazil: main economic indicators

Indicator	Value	Source
GDP (2024)	approx. USD 2,200 B	[1]
GDP per capita	approx. R\$ 55,250	[1]
Population at high risk from lack of cooling	34.2 M	[25]
Rural poor in population at high risk from lack of cooling	approx. 4.3 M	[25]
AC share of residential electricity (2023)	approx. 17%	[21]
Reported fruit-and-vegetable losses	Highly variable by commodity and supply-chain stage	[26][27]
Cold-chain logistics market (2026 est.)	approx. USD 5.64 bn (commercial est.)	[28]

Electricity system

The Brazilian electricity system is large, overwhelmingly renewable and hydro-dominated, which keeps the indirect, grid-related emissions of cooling comparatively low but exposes cooling demand to hydrological and seasonal risk.

As represented in Figure 4, hydropower supplied about 56.1% of electricity and renewables about 88.3% of the generation mix in 2024, while wind and solar together reached approximately 23.7% [12]. Total generation was 751.3 TWh [12] and final electricity consumption was 650.4 TWh [20]. The grid emission factor was correspondingly low, at 59.9 kg CO₂e/MWh [20]. This profile shifts the climate case for efficient cooling toward



the management of direct refrigerant emissions and peak demand. Final electricity consumption rose by 5.5% year on year, with the residential segment up 8.0%, a movement attributed in part to more intensive use of fans and air conditioners during heat waves [20][21]. Key indicators are reported in Table 5.

Table 5 – Brazil: electricity system key indicators

Indicator	Value	Source
National electrification rate	approx.100% (rural 97.3%)	[10]
Renewable share of electricity	approx. 88.3%	[12]
Hydropower share of supply	56.1%	[12]
Wind + solar share of generation	approx. 23.7%	[12]
Grid reliability – DEC, avg. interruption duration (2024)	10.24 h/yr avg. interruption	[16]
Grid reliability – FEC, avg. interruption frequency (2024)	4.89 interruptions/yr	[16]
Residential electricity tariff	Varies by distribution area and tax treatment	[18]
Yearly residential electricity consumption growth	+8%	[20]
Grid emission factor	59.9 kgCO ₂ eq/MWh (2024)	[20]




Figure 4 – Brazil: electricity production share [12]

The Manaus Free Trade Zone and the domestic RAC industry

A structural feature of the Brazilian market is that most room air conditioners are manufactured domestically, largely through assembly of semi-knocked-down and completely-knocked-down kits in the Manaus Free Trade Zone (Zona Franca de Manaus) [29]. This shapes the available policy levers. Minimum performance standards and refrigerant transitions act on local production lines and a domestic supply chain rather than on a stream of finished imports. Fiscal incentives are tied to the Free Trade Zone regime rather than to import tariffs alone and the HFC phase-down interacts directly with industrial conversion programmes for compressors and charging lines. The wider refrigeration and air-conditioning industry is economically significant: the industry association forecast turnover of approximately R\$ 41 billion for 2024 [30]. Because production capacity already exists onshore, efficiency and refrigerant policy can be implemented through the domestic industrial base, which is treated further in the market-entry section.

Regulatory Framework

Key legislation

Brazil has a long-established framework for appliance energy efficiency and for the ozone and HFC agenda. It does not yet have a dedicated national cooling plan in force: the participatory preparation of the Plano Nacional de Ação pelo Resfriamento was formally launched in March 2026 [15]. Energy efficiency rests on the Energy Efficiency Law (Lei 10.295/2001) and is implemented through PROCEL and the Brazilian Labeling



Program (PBE) administered by INMETRO. Refrigerant controls operate through the Brazilian HCFC Elimination Program (PBH), IBAMA import procedures and the Montreal Protocol and Kigali instruments.

The principal instruments are summarised in Table 6.

Table 6 – Brazil: list of administrative key provisions

Instrument	Year	Key provision
Energy Efficiency Law 10.295	2001	Legal basis for minimum efficiency levels of energy-using equipment
PBE / ENCE labelling	ongoing	Mandatory ENCE energy labeling for regulated AC and refrigerator categories, administered by INMETRO [19]
INMETRO Portaria 269, as amended	2021–2025	IDRS-based AC energy classification and conformity requirements; current consolidated scope must be checked [19]
CGIEE Resolution No. 1 (Programa de Metas)	2022	Minimum IDRS levels for room ACs; removes lowest classes from the market [11]
Programa Brasileiro de Eliminação dos HCFCs (PBH)	2010–2030 Stage III	HCFC phase-out schedule; final stage targets 100% consumption elimination by 2030 [13]
Decreto 11.666 (Kigali Amendment)	2023	Promulgation of the HFC phase-down commitments [14]
Plano Nacional de Ação pelo Resfriamento	under preparation from 2026	Participatory intersectoral cooling strategy; not yet in force [15]

The revision of the Brazilian Energy Labeling Program for air conditioners began with INMETRO Ordinance No. 234 of 29 June 2020 and was consolidated by Ordinance No. 269 of 22 June 2021, subsequently amended, including by Ordinance No. 672 of 2025 [19]. These measures introduced the IDRS-based classification and conformity framework. The corresponding binding minimum-performance thresholds were approved by the CGIEE through Resolution No. 1 of 29 April 2022 [11]. Applicants should use the current consolidated INMETRO text and product tables rather than relying on an earlier label class or an isolated ordinance.

MEPS in force for cooling appliances

Minimum energy performance requirements and PBE/ENCE labeling apply only to products within the relevant regulated scope. Room air conditioners and specified refrigerator and freezer categories are covered, but conformity assessment, registration and labeling requirements remain product-specific. Commercial refrigeration equipment should therefore be checked against the current INMETRO scope before procurement [11][19][21]. Technical standards issued by ABNT should be treated separately from product-market



authorization: their applicability may arise through regulation, building and fire requirements, procurement documents, contracts or professional duties and must be confirmed for the specific project.

Table 7 – Brazil: MEPS in force for cooling appliances

Product	Instrument	Key requirement
Room air conditioners	INMETRO 269/2021, as amended, + CGIEE Res. 1/2022	IDRS-based label and mandatory minimum performance levels; use the current consolidated requirements [11][19]
Regulated refrigerators and freezers	PBE / ENCE, where covered	Energy labeling, minimum performance and registration apply only to covered categories; verify the exact product scope [19][21]
Conformity / market entry	INMETRO conformity assessment, where regulated	For regulated products, certification or registration and ENCE are required before sale, as applicable [19]

Refrigerant transition timeline

Brazil follows the Montreal Protocol and the Kigali Amendment. HCFCs, including R-22, are governed by the PBH and IBAMA controls, and the final PBH stage targets elimination of HCFC consumption by 2030. HFC consumption was frozen in 2024 and is scheduled for phased reductions through 2045 [13][14]. R-32 and lower-GWP or natural refrigerants such as R-290, CO₂ (R-744) and ammonia (R-717) are technology pathways rather than blanket legal prescriptions. IBAMA quota and authorization procedures apply to controlled HCFCs, HFCs and mixtures as specified by the applicable rules; natural refrigerants are not subject to HFC or HCFC quotas solely because they are used as refrigerants, although product, safety, transport, installation and maintenance requirements remain applicable [13]. The milestones are set out in Table 8.

Table 8 – Brazil: refrigerant transition targets

Milestone	Target
HCFC consumption reductions (PBH)	–39.3% (2020), –51.6% (2021) vs baseline [13]
HCFC total elimination	2030 [13]
HFC phase-down (Kigali): freeze	2024 [14]
HFC phase-down, reductions	–10% (2029), –30% (2035), –50% (2040), –80% (2045) [14]
Common transition option in split ACs	R-32, subject to product and safety requirements [13]
Lower-GWP options in commercial/industrial systems	R-290, CO ₂ (R-744) and NH ₃ , subject to application-specific requirements [13]

Key institutions

Oversight is distributed across several federal authorities, summarised in Table 9.

Table 9 – Brazil: cooling key authorities

Authority	Role for cooling
MME / EPE	Energy policy and planning; Balanço Energético Nacional; efficiency analysis [20][21]
INMETRO	PBE labelling, MEPS, conformity assessment and product registration for regulated categories [19]



Authority	Role for cooling
ANEEL	Electricity tariffs and distribution service quality (DEC/FEC) [16][18]
MMA / IBAMA	PBH, HFC phase-down and import controls for refrigerants and other Montreal Protocol substances [13][14]
Receita Federal	Customs, import tax (II), IPI, PIS/COFINS-Importação [31]
ANVISA	Health-product cold chain and medical-device regulation in the health sector [32]

The customs and tariff functions operate within a domestic-manufacturing and Mercosur setting rather than a pure import-conformity regime, which reflects the weight of local production noted earlier.

Market entry: what to do before importing or installing equipment in Brazil

Because a large share of the room-AC market is assembled domestically in Manaus [29], direct importation is only one route to market. Imported equipment is classified under the Mercosur Common Nomenclature (NCM) and may be subject to Import Duty (II), IPI, PIS/COFINS-Importação and state ICMS. INMETRO conformity assessment applies only where the specific product falls within a regulated scope. Table 10 is therefore indicative: exact tariff treatment, licensing and conformity requirements must be checked using the current eight-digit NCM and the applicable product regulation before budgeting [19][31][33][34].

Table 10 – Brazil: indicative import requirements and charges

Charge	Working assumption
Import duty (II), ACs (NCM 8415)	Indicative rate often 10–20%; confirm the exact eight-digit NCM and current TEC [31][33][34]
Import duty (II), refrigeration (NCM 8418)	Indicative rate often 10–20%; confirm the exact eight-digit NCM and current TEC [31][33][34]
IPI (excise)	Product-specific; often 0–15%, to be confirmed by NCM and current TIPI [31][33]
PIS/COFINS-Importação	General goods rate commonly 2.1% + 9.65%, subject to legal exceptions and product treatment [31][33]
ICMS (state VAT)	State-specific; often 17–25%, with the rate and calculation rules varying by state and transaction [31][33]
INMETRO conformity	Required only for products within an INMETRO-regulated scope; certification or registration and ENCE apply as specified [19]
Refrigerant import	HCFCs, HFCs and other controlled substances require the applicable IBAMA authorisation and quota or registration procedures [13]
Manaus Free Trade Zone	Tax incentives for local assembly, distinct from the import regime [29]
Ex-Tarifário (duty relief)	Temporary II reduction for eligible BK/BIT goods without equivalent domestic production; advance application required [35]
Importer of record	A Brazilian legal entity or importer is generally required for Siscomex habilitation and the applicable import declaration; conformity requirements remain product-specific [33][34]
INMETRO certification planning	Product-, documentation- and laboratory-dependent; confirm the pathway and timing with an accredited certification body before procurement [19]



Charge	Working assumption
Smart controls, BMS, IoT	ANATEL homologation is required where radio-frequency or telecommunications functionality falls within the regulated product scope [36]
Pressure / industrial systems	NR-13 applies to covered pressure equipment and piping; regulated engineering services require CONFEA/CREA responsibility and ART [37][38]
Climate / efficiency financing	BNDES Fundo Clima may support eligible climate-aligned machinery and projects; state incentives are case-specific [31][39]

Routing to market in practice normally requires a Brazilian legal entity or importer habilitated in Siscomex. The applicable import declaration is the DUIMP or, during the system transition, the DI, depending on the operation and current implementation timetable [33][34]. For products within an INMETRO-regulated scope, Brazilian conformity assessment, registration and ENCE labeling must be completed as applicable; CE marking and foreign test reports do not replace these requirements, although technical evidence may support the conformity process [19]. Certification timing is product-, documentation- and laboratory-dependent and should be confirmed with an accredited Brazilian certification body before procurement. Wireless or radio-frequency controls require ANATEL homologation where they fall within the telecommunications-product scope [36]. NR-13 applies to covered boilers, pressure vessels, piping and metallic storage tanks, while regulated engineering services require a responsible professional and the relevant ART under the CONFEA/CREA system [37][38]. Imports of controlled HCFCs, HFCs and covered mixtures require the applicable IBAMA authorization, registration and quota procedures [13].

Several mechanisms can lower landed cost. The Ex-Tarifário regime can temporarily reduce import duty for eligible capital goods and information-technology or telecommunications goods, including qualifying parts and components, where there is no equivalent national production; eligibility is not automatic and the process requires advance planning [35]. BNDES Fundo Clima may finance eligible machinery, equipment or investment projects linked to greenhouse-gas reduction and climate adaptation [39]. State ICMS incentives, where available, remain project- and state-specific [31][33].

Behavioural Context

Cooling in Brazil is shifting in perception from a comfort and status good towards a necessity, but it does so from a higher baseline of ownership than in most lower-income markets and within a highly unequal distribution. Air-conditioner ownership remains comparatively low overall, at roughly 20% of households against near-universal refrigerator ownership of about 98% [21], and it is strongly stratified by income, reported above 60% in the highest bracket and far lower among poorer households, so any policy that lowers the cost of efficient cooling carries a direct equity dimension [21][30]. Heat-wave episodes now produce visible spikes in residential electricity use [20][21], and exposure falls disproportionately on favela residents, outdoor and informal workers, the elderly and pregnant women. Brazil's continental climate, deep inequality, clean grid and domestic appliance industry together set the conditions for the sectoral demand examined in the following chapters.

Tertiary-Sector Cooling

Healthcare

System infrastructure and facility inventories

Brazil operates the Sistema Único de Saúde (SUS), a universal and decentralised system spanning the federal, state and municipal levels, alongside a substantial private and supplementary sector [40]. Facilities and beds



are recorded in the National Registry of Health Establishments (CNES) maintained by DATASUS. National provision stands at about 2.5 hospital beds per 1,000 inhabitants [41], under the global average of 3.3, with wide regional dispersion, with provision falling below the national average across much of the North and North-East and reaching the upper end of the range at about 2.71 in Rio Grande do Sul, 2.78 in the Federal District and 3.01 in Rondônia per 1,000 [42]. On the basis of the Ministério da Saúde open dataset, the estate with inpatient capacity comprises about 7,200 facilities and roughly 522,000 beds and cots, of which just under 3,000 facilities are hospitals with more than 50 beds [43]; the CNES universe of establishments is far larger once primary-care units without beds are included [42]. A facility-type breakdown by size band, with counts and bed capacity, is proposed in Table 11.

Table 11 – Brazil: healthcare facilities classification (elaboration on Ministério da Saúde open data, “Hospitais e Leitos” [43])

Healthcare Facility Type	Description	Facilities	Total capacity	Average capacity
			Hospital beds + cots	Hospital beds + cots
Community / Basic Healthcare Facility	Not a hospital or Hospital beds ≤ 50	4,228	101,046	23.90
Small district hospital	$50 < \text{Hospital beds} \leq 150$	2,083	181,176	86.98
Medium hospital	$150 < \text{Hospital beds} \leq 300$	680	139,563	205.24
Large hospital	$300 < \text{Hospital beds} \leq 500$	173	64,139	370.75
Referral / Tertiary sector hospital	Hospital beds > 500	48	35,678	743.29

The geography of provision matters for cooling because the regions with the highest thermal stress, in the North and North-East, are also those with comparatively thinner hospital infrastructure and tighter municipal budgets, as represented in Figure 5.




Figure 5 – Brazil: hospital facilities location vs cooling degree days 18°C distribution

Any expansion of capacity in these regions will embed new cooling load, and the specification of that load at the design stage will determine operating costs and emissions for decades. The supplementary private hospital sector, by contrast, is concentrated in the wealthier south-east and continues to expand, which drives demand for higher-specification climate control in new and refurbished units [44].




Figure 6 – Brazil: inpatient bed distribution across facilities [43]

The distribution of facilities is strongly skewed. The large majority are small community and basic-health units, while hospitals with more than 50 beds, and especially medium and large hospitals, are comparatively few yet hold most of the inpatient and specialised capacity. This mirrors the design of the SUS, which pairs a broad, capillary network of primary-care units for first-contact and preventive care with a smaller set of mid- and high-complexity hospitals concentrated in the larger cities, predominantly in the South-East [40][45]. For cooling, it implies that basic-comfort and vaccine-storage needs are dispersed across many small facilities, whereas clinical-grade air treatment and chilled-water cooling are concentrated in the larger hospitals.

The cooling deficit and clinical consequences

In healthcare, cooling is an operational requirement rather than a matter of comfort, and its functions fall into three domains summarised in Table 12.

Table 12 – Brazil: healthcare cooling applications

Domain	Requirement	Evidence / response
Vaccine cold chain (2 – 8 °C)	Continuous temperature control across the PNI rede de frio	The national central store (CENADI) operates about 17,600 m ³ of refrigerated capacity at +2/+8 °C and about 2,646 m ³ at –20 °C; immunobiologicals flow from CENADI through the 27 state central stores and municipal networks down to local vaccination rooms, with every tier dependent on continuous refrigeration [40][46].
Medical storage & labs	24-hour climate control for pharmaceuticals, blood products and reagents	Storage and transport of temperature-controlled medicines are governed by ANVISA good-practice rules (RDC 430/2020); blood components are regulated by RDC 34/2014. Both require documented, continuous temperature control, so a refrigeration failure interrupts pharmacy, laboratory and transfusion services [32].
Clinical thermal comfort	Stable temperature and humidity in wards, ICU and surgery; air changes and pressurisation per NBR 7256.	A nationwide study covering 1,814 cities (2000–2015) found that hospitalisation risk rises by 4.0% for every +5 °C of daily mean temperature in the hot season, with about 6.2% of hot-season admissions attributable to heat; the burden peaks in the centre-west and the interior north-east, the same regions with the highest cooling demand [47].

The vaccine cold chain is anchored by the National Immunization Program (PNI), which operates a temperature-controlled 'rede de frio' from national and state stores to local vaccination units; the current PNI



manual is the sixth edition published in 2025 [40][46]. The clinical estate also imposes requirements beyond simple temperature setpoints. Operating rooms, intensive-care units and isolation rooms require controlled humidity, air-change rates and, for specific spaces, pressurization. ABNT NBR 7256:2021, including Amendment 1:2022, is the principal Brazilian technical reference for air treatment in healthcare establishments [48]. Its project-specific legal or contractual applicability should be confirmed. In the hot-humid North and coastal zones, dehumidification represents a substantial part of the load, so latent capacity and air quality, not temperature alone, drive equipment sizing.

Current market conditions and technology

Common technology configurations in medium and large hospitals include central chilled-water plants, while VRF, direct-expansion split and self-contained units are used in wards, clinics, administrative areas and smaller facilities. The precise configuration varies by facility, climate and clinical function. Manufacturer documentation confirms that current product pathways include R-513A options for selected chillers and R-32 options for several unitary and VRF product families [49]. Indicative performance ranges are reproduced in Table 13 and should be verified against the current equipment class, rating conditions and applicable efficiency requirements.

Table 13 – Brazil: healthcare cooling technology benchmark

Technology	COP	EER [W/W]	Notes
Modern centrifugal chillers	> 6.0	> 5.5	Indicative high-efficiency range for large chillers; verify equipment class, rating conditions and the current ASHRAE 90.1 edition [50]
Inverter VRF	4.0–5.0	3.5–4.5	Indicative part-load range; not a universal minimum requirement [50]
Conventional split	3.0–3.4	2.8–3.2	Indicative rated range for the PBE-labeled segment; verify current IDRS class [19]
Automation / predictive control	+15–20%	+15–20%	Operational optimisation; industry estimates [30]

Infrastructure demand projections

The calculation is an illustrative capacity-expansion scenario. It combines expected population growth with a selected benchmark of approximately 3.3 hospital beds per 1,000 inhabitants and preserves the current modeled distribution of facilities by size band [41]. It is not a forecast of approved hospital construction or a statement of a legally required capacity level; actual investment needs will depend on service organization, occupancy, outpatient provision and regional access.

New facilities = (population growth × current hospital beds per capita × current facility-type ratio) / average facility size

Holding the modeled facility-type mix constant, Figure 7 shows the additional facilities implied by this illustrative 2050 scenario. The values are screening outputs, not an approved investment pipeline or a regional allocation.




Figure 7 – Brazil: current and additional facility number by size

Under the illustrative scenario, preserving the current modeled distribution of facility types yields approximately 783 additional small district hospitals, 256 medium hospitals, 65 large hospitals and 18 referral hospitals by 2050. These values indicate the order of magnitude of potential capacity expansion and associated cooling demand; they are not a forecast or a minimum construction requirement, and no regional allocation has been modeled.

Technology baseline and refrigerant mix

The current technology baseline in Brazil's healthcare cooling sector reflects a market at an early stage of transition, with a predominance of low-efficiency equipment and a refrigerant mix still weighted toward higher-GWP options. Key indicators are summarised in Table 14.

Table 14 – Brazil: healthcare cooling technology indicators

Indicator	Value	Source
HVAC share of electricity, large hospitals	≈ 41%	[45]
Cooling share of electricity, facilities > 50 beds	≈ 28.6%	[45]
Specific total energy consumption (large-hospital sample, monthly)	≈ 3,301 kWh/bed-month	[45]
Dominant plant type, medium and large hospitals	Central chilled-water plants	[45]
Reference refrigerant, centralised chillers	R-134a; transition to R-513A under way	[49]
Dominant technology, wards and small units	DX split and VRF on R-410A; transition to R-32	[49]

Despite the dominance of split units, the centralised chiller segment is growing.

Energy implications

It has been estimated in this assessment, using the hospital electricity intensities in Table 15 [45], that electricity consumption in facilities with more than 50 beds is about 6.24 TWh/yr, of which cooling accounts for roughly 28.6%, or 1.78 TWh/yr, equivalent to about 4% of national public-services electricity consumption [20]. Applying the 2024 grid emission factor and the refrigerant-leakage assumptions below, the cooling-related GHG emissions are about 0.327 Mt CO₂eq/yr (0.220 direct plus 0.107 indirect) [20][45][51].



Energy consumption and emissions in the healthcare sector are parameterized using hospital bed count as the primary proxy. At the national level, beds per 1,000 inhabitants is a widely available indicator of healthcare-system capacity. At facility level, bed capacity is associated with infrastructure complexity, but it does not capture climate, occupancy, clinical services or operating practice. Primary-care practices and pharmacies are excluded from the quantified energy assessment. The 28.6% cooling share and the annual electricity intensities in Table 15 are derived by converting the published study’s monthly total-energy benchmarks using its reported electricity and air-conditioning shares [45]. Because the study is based on an older facility sample and the size-band model uses different service assumptions, its values are used as screening benchmarks rather than as a current national metered inventory; applicants should validate loads and intensities at site level.

The corresponding energy consumption values used, along with their respective references and explanation, are presented in Table 15:

Table 15 – Healthcare reference specific energy consumption [45]

Healthcare Facility Type	Level	Hospital electricity consumption [kWh/bed-yr]	Hospital electricity consumption for cooling [kWh/bed-yr]	Notes
Small district hospital	1	8,875.07	2,204.57	Brazilian average for small district hospitals.
Medium hospital	2	18,344.88	4,995.31	Brazilian average for medium hospitals with high comfort level. The underlying hypothesis is that overall comfort level has increased in the hospital band with 150-450 hospital beds
Large hospital	3	18,344.88	4,995.31	Brazilian average for medium hospitals with high comfort level
Referral / Tertiary sector hospital	4	25,193.23	10,334.26	Brazilian average for large hospitals

Facility-level GHG emissions are assessed as the sum of indirect contributions (electricity consumption) and direct contributions (refrigerant leakage).

Indirect emissions are calculated as the product of electricity consumption and the national grid emission factor.

For direct emissions, the estimated facility stock and modeled plant sizes are used to construct a screening scenario. The system type, specific refrigerant charge and annual service-emission factor shown in Table 16 are explicit model assumptions rather than observed Brazilian national averages. Project applications should replace them with equipment-specific charge, service records and leakage data wherever available.



Table 16 – Healthcare cooling plant characteristics used as screening assumptions

Healthcare Facility Type	Level	Typical cooling system	Assumed average plant size [MW]	Assumed specific refrigerant charge [kg refrigerant/kW installed]	Assumed annual service-emission factor [kg refrigerant leaked/kg charge-yr]
Small district hospital	1	Mostly VRF and DX split units; one or two small modular chillers with AHUs and fan-coils may serve the operating block and the ICU	0.75	0.14	22%
Medium hospital	2	Chilled water plants	2.5	0.14	22%
Large hospital	3	Chilled water plants	5.7	0.14	22%
Referral / Tertiary sector hospital	4	Chilled water plants	15.3	0.14	22%

Emission figures are calculated taking R-134a as the reference refrigerant across centralised chiller installations, giving an average GWP of about 1,430 [51], with an electricity grid emission factor of 0.06 kgCO₂eq/kWh [20]. On this basis the sector's cooling-related emissions are about 0.327 Mt CO₂eq per year, of which roughly 0.220 Mt is direct (refrigerant leakage) and 0.107 Mt indirect (electricity). Although modest in national terms, these values underline the importance of embedding energy-efficient and low-GWP refrigerant standards in any healthcare infrastructure investment programme, both to contain facility operating costs and to support alignment with Brazil's NDC commitment [17].

Structural barriers to investment

The principal barriers and the corresponding pathways are summarised in Table 17.

Table 17 – Brazil: barriers to the deployment of cooling technologies in the healthcare sector

Barrier	Detail
Low-efficiency installed base	Conventional fixed-speed splits and ageing chillers dominate the installed base. As HCFC supply tightens under the PBH quotas, servicing costs rise and replacement becomes unavoidable [13].
High upfront capital cost for small and medium SUS units	Municipal and small SUS units operate under constrained capital budgets and lowest-price procurement, which selects against higher-efficiency equipment with lower life-cycle cost; financing costs are high for private operators as well [44].
Direct refrigerant emissions dominate under a clean grid	With a grid emission factor near 0.06 kgCO ₂ eq/kWh [20], leakage of high-GWP refrigerants outweighs indirect emissions, so refrigerant choice, leak-tightness and end-of-life recovery become the primary mitigation levers [14].
Resilience of the PNI rede de frio to outages	Average distribution outages of 10.24 hours per year (DEC, 2024) [16], higher in the North, expose vaccine and pharmaceutical stores to temperature excursions unless backup power, autonomy and monitoring are specified [46].



Technology pathways

Brazil's national cooling plan (Plano Nacional de Ação pelo Resfriamento) is still being drafted, with the process launched in March 2026 [15]. Pending its publication, the directions below draw on the PBH and Kigali instruments [13][14], on the INMETRO efficiency framework [11][19] and on current sector practice. For project developers they provide a procurement reference and a basis for demonstrating regulatory alignment in climate-finance applications. The recommended pathways are summarised in Table 18.

Table 18 – Brazil: technology pathway for healthcare cooling applications

Application	Recommended technology direction
General space cooling: wards, clinics and administrative areas	Inverter-driven splits, VRF, mini-chillers
Central plants and critical areas (ICU, operating theatres) in medium and large hospitals	Semi-centralised systems with heat recovery, enthalpic recuperators, TES; target 21–23 °C, 40–60% RH
Medical and pharmaceutical storage, laboratories	High-efficiency units, R290 or CO ₂ , digital monitoring, 2–8 °C continuous
Vaccine cold chain (PNI rede de frio), remote and outage-prone units	Solar Direct Drive (SDD) refrigerators with battery/thermal storage

Quick summary

The key barriers and enablers for sustainable cooling investment in the healthcare sector are summarised in Table 19.

Table 19 – Brazil: healthcare cooling quick summary

Dimension	Barriers	Enablers
Technology	Stock dominated by fixed-speed splits and ageing chillers	Inverter VRF, high-efficiency chillers, low-GWP refrigerants (R-32, R-513A, R-290, CO ₂) [13][14][49]
Economics and finance	High upfront cost for SUS units; lowest-price procurement	Cooling-as-a-service, on-bill repayment, development finance aligned with the NDC [17][44]
Regulation	No sector cooling plan yet in force; Plano Nacional de Ação pelo Resfriamento in preparation [15]	INMETRO MEPS and labelling in force [11][19]; NBR 7256 air-treatment standard [48]
Infrastructure and resilience	Supply is generally reliable (distribution outages at 10.24 h/yr), but even short outages can compromise critical vaccine and blood cold chains, which justifies battery or solar backup for those loads [16]	Solar-assisted and battery-backed cold chain, SDD refrigerators, digital monitoring [46]
Data	Healthcare-specific stock, refrigerant mix and R-22 share not quantified	CNES-based facility inventory and submetering programmes [42][43]



Education

System structure and context

Brazil's basic-education system enrolls about 47.1 million students across roughly 179,300 schools, supported by 2.4 million teachers [52]. The regions of highest cooling demand in the North, North-East and central interior coincide with weaker infrastructure, but the sector's distinctive problem is the low and highly unequal penetration of classroom climatisation within a system that is otherwise close to universally electrified. Key indicators are summarised in Table 20.

Table 20 – Brazil: education sector key indicators

Indicator	Value	Source
Basic-education enrolment	47.1 M	[52]
Number of schools	179,300	[52]
Classrooms with cooling/AC (national)	41.1% public / 53.2% private ($\approx 44.9\%$ overall)	[53]
Worst state penetration (SP state network)	$\approx 4.1\%$ (São Paulo capital municipal network 1.2%)	[53]
Classrooms without mechanical cooling	$\approx 55\%$ (fans and natural ventilation only)	[53]
Basic infrastructure (water/energy/sanitation)	Water, electricity and sanitation are near-universal in the school network; the remaining deficits concern thermal comfort and digital connectivity, which lag despite electrification	[54]

A further Brazilian feature compounds the exposure. Most public schools operate on multiple daily shifts, so a large share of teaching takes place in the afternoon, when indoor temperatures peak. The combination of afternoon occupancy, lightweight roofing and limited shading means that the hours of greatest learning effort frequently coincide with the hours of greatest heat stress.

An analysis of the 2024 INEP School Census microdata reports that 41.1% of classrooms in public schools and 53.2% in private schools were recorded as climatised, approximately 44.9% overall [52][53]. The Census variable includes functioning equipment used to maintain thermal conditions and should not be interpreted as proof that every classroom is air-conditioned or that design ventilation requirements are met. The regional distribution remains strongly unequal, and the reported regional adoption rates are used as model inputs below.

Figure 8 maps facilities against thermal stress.




Figure 8 – Brazil: Education facilities location vs cooling degree days 18°C distribution

The overlay shows that many schools lie in the high-CDD North and North-East, where cooling needs are greatest while climatisation rates and grid resources are weakest. Education cooling demand is therefore concentrated where the system is least able to meet it, reinforcing the regressive pattern noted above.



The thermal problem

Brazilian classrooms experience pronounced overheating, a problem widely described in public debate as 'saunas de aula'. Mechanical cooling is absent from over half of classrooms ($\approx 55\%$ nationally on the 2024 Census microdata)[52], and where it is missing the only mitigation is fans [53][55]. Excess heat is associated with reduced cognitive performance and weaker learning outcomes, and the burden is regionally regressive, since the hottest areas are also the least climatized [23][53]. Where air conditioning is installed, cooling becomes one of the dominant electricity end uses in Brazilian schools, substantially increasing overall building energy consumption, particularly during periods of extreme heat [56][57]. Several states and municipalities have launched classroom-climatization programmes in response, although coverage remains partial and uneven [53].

Market trajectory

Indicative efficiencies, consistent with the PBE/INMETRO labelled ranges, are given in Table 21 [19].

Table 21 – Brazil: education cooling technology benchmarks

Technology	EER [W/W]	Notes
Modern inverter split	3.5–4.2	Up to 40% less energy than conventional units [19]
Conventional split (on/off)	2.6–3.0	Common in lowest-price tenders [19]
Window AC (ACJ)	2.4–2.8	Obsolete on efficiency and noise [19]
Evaporative cooler	n/a	Up to 90% lower energy; limited cooling effect [19]

Demand is widely expected to rise steeply, and classroom cooling demand could roughly triple by 2050 as warming and the expansion of climatized floor space combine [58][59]. The procurement model matters as much as the equipment: lowest-price public tenders tend to favour conventional on/off units, which locks in low efficiency for the equipment's full service life, so efficiency criteria in tender design are a decisive lever.

Demand Estimation Methodology

Cooling energy demand was estimated through a bottom-up model structured around Brazil's educational system. Two distinct methodologies are applied, reflecting the different cooling technology assumptions for university and non-university facilities. For universities, a centralised chiller system is assumed as the reference technology. For all other education levels, split and multi-split systems serving individual classrooms are used as the reference configuration.

For non-university facilities, the methodology follows three sequential steps: thermal-load characterization per classroom, estimation of annual operating hours by macro-region and aggregation by education level. Plant load is the sum of net outdoor-air load, internal gains and envelope transmission. Three climatic zones are distinguished with zone-specific design conditions. The 7.4 and 10.3 L/s per person cases use values reported in the 2024 edition of ABNT NBR 16401-3 for the stated classroom density [60]. That edition was subsequently suspended in 2025; the values are therefore retained only as transparent illustrative ventilation benchmarks, not presented as current mandatory requirements. Applicants must verify the standard edition and legal or contractual requirements in force when designing a project. The prevailing hi-wall split stock generally recirculates room air and introduces little dedicated outdoor air, so the installed-stock case is reported separately.



Table 22 – Brazil: assumed design parameters for an education plant

Parameter	Value	Reference
Ventilation rate	7.4 l/s per person (700 ppm); 10.3 (500 ppm)	Illustrative values from ABNT NBR 16401-3:2024; that edition was suspended in 2025, so current status must be verified [60]
Indoor set-point temperature	24 °C	Model design assumption; verify the applicable comfort and health requirements
Outdoor design temperature	35 / 37 / 33 °C (Z1 / Z2 / Z3)	Design assumption by zone
Indoor absolute humidity	12 g/m ³ (24 °C, ≈55% RH)	Design assumption
Outdoor absolute humidity	23 / 16 / 15 g/m ³ (Z1 / Z2 / Z3)	Design assumption by zone
Building envelope U-value (average)	4 W/m ² K	Design assumption
Average split system COP	3.1	Stock average, PBE/INMETRO labelled ranges [19]

The resulting plant sizes by education level, derived from occupant loads, ventilation loads, and transmission loads, are reported in Table 23; values are zone-weighted averages on the climatized stock (42.9% Z1, 11.4% Z2, 45.6% Z3), and the outdoor-air column is net of the supply-air cooling credit.

Table 23 – Brazil: classroom characteristics (zone-weighted averages from the classroom thermal model)

Level	Occupants per classroom	Occupant load [kW _{th}]	Net outdoor-air load [kW _{th}]	Transmission load [kW _{th}]	Total thermal load [kW _{th}]	Electrical plant size [kW _{el}]
Primary	20	4.00	4.26	1.24	9.49	3.06
Secondary	25	5.00	5.32	1.55	11.87	3.83

Tertiary education is treated separately with the centralised-plant approach; only the in-person share of enrolment generates classroom cooling demand, with distance learning excluded [61].

Annual cooling hours are estimated by weighting the five macro-regions by their share of classrooms. The AC adoption rate is not assumed but measured: it is taken region by region from the 2024 School Census microdata, public and private networks combined [53]. The share of school days with active cooling is assigned per region by climate. The school year is set at 200 teaching days, the statutory minimum under the LDB (Lei 9.394/1996, art. 24) [62], with 8 building-operation hours per day reflecting the prevalent two-shift pattern, in which the afternoon shift coincides with peak heat. The regional assumptions are set out in Table 24.

Table 24 – Brazil: assumed cooling technologies adoption and utilization [53]

Climatic zone	Share of classrooms	AC adoption rate	Days with active cooling
North	8.5%	69.9%	95% of school days
North-East	27.4%	48.7%	80% of school days
Centre-West	7.5%	68.5%	75% of school days
South-East	40.5%	28.0%	50% of school days



Climatic zone	Share of classrooms	AC adoption rate	Days with active cooling
South	16.1%	56.9%	40% of school days
Weighted average	100%	44.9%	65.7% of school days (weighted on climatised classrooms)

The resulting annual cooling hours, weighted on the climatised stock, are about 1,051 hours per year. The classroom count is converted from class groups (turmas) to physical rooms through a multi-shift factor of 0.93, anchored to the 1,509,908 classrooms recorded by the 2024 School Census [52][53].

$$\text{Energy [GWh]} = \text{No. classrooms} \times \text{adoption rate} \times \text{electrical plant size [kW}_e\text{]} \times \text{annual cooling hours [h]} \times \text{load factor}$$

Where the load factor (0.7) reflects compressor cycling and modulation below nameplate output during operating hours.

For the tertiary sector, consumption is estimated from the in-person enrolment of about 5.0 million students, i.e. 49.3% of approximately 10.23 million total enrolments: distance learning, which surpassed in-person enrolment in 2024, generates no classroom cooling demand [61]. A specific load of 200 W per student is applied, with a design oversizing factor of 1.15, a distribution efficiency of 0.9, an annual equivalent occupancy of 630 hours and a centralised-plant COP of 2.8. The resulting energy consumption breakdown by education subsector is illustrated in Figure 9.




Figure 9 – Brazil: Cooling energy demand by education subsector

The estimated current installed-stock consumption is approximately 1,667 GWh per year (Table 27). Applying the illustrative 7.4 L/s per person ventilation benchmark raises the model result to approximately 2,023 GWh per year: 713 GWh in primary, 1,019 GWh in secondary and 292 GWh in tertiary facilities. This is approximately 0.31% of Brazil's 2024 final electricity consumption [20]. The implied average for primary and secondary education is about 2,750 kWh per climatised classroom per year, consistent with the stated equipment size and approximately 1,000 annual operating hours under the model assumptions.

Emissions Estimation

Total emissions are the sum of indirect emissions from electricity consumption and direct emissions from refrigerant leakage. Indirect emissions apply the Brazilian grid emission factor of 0.0599 t CO₂e/MWh (2024) [20] to the estimated consumption, yielding about 121 kt CO₂e per year. Direct emissions are calculated as installed electrical cooling capacity × specific refrigerant charge × annual leakage rate × mixture-weighted GWP. For schools, the screening scenario assumes 0.56 kg of refrigerant per kW installed and 15% annual



leakage, with the split-system mix in Table 25. For centralised tertiary plants, it assumes 0.90 kg/kW and 10% annual leakage with an illustrative equal mix of R-134a, R-410A and R-513A. These are explicit modelling assumptions, not measured national averages; the product pathways are informed by current technical documentation [49], and GWP values use a consistent IPCC AR4 basis [51].

Table 25 – Brazil: assumed split and multi-split refrigerant mix for the emissions scenario

Refrigerant	Assumed share	GWP (AR4)
R-410A	65%	2,088
R-32	30%	675
R-22 (legacy)	5%	1,810
Weighted average GWP	100%	1,650

The resulting emissions breakdown is summarised in Table 26.

Table 26 – Brazil: modeled education-sector emissions summary

Emission component	Value [ktonCO ₂ /year]
Indirect emissions – electricity consumption	121.2
Direct emissions – refrigerant leakage (schools)	324.8
Direct emissions – refrigerant leakage (tertiary, centralised plants)	57.3
Total estimated emissions	503.3

Total estimated emissions of approximately 503 ktonCO₂eq per year are dominated by refrigerant leakage, which accounts for about 76% of the total. With a grid emission factor an order of magnitude below fossil-heavy systems, the climate impact of school cooling in Brazil is primarily a refrigerant question rather than an electricity question, which points to low-GWP refrigerants, leak-tight installation and end-of-life recovery as the first-order levers. The estimate is also a lower bound on latent demand: with adoption measured at 44.9% of classrooms [53], convergence towards full climatization under current technology would more than double school consumption and direct emissions, before accounting for climate-driven growth in cooling hours.

Table 27 – Brazil: modeled education cooling consumption and emissions under illustrative ventilation scenarios

Ventilation scenario	Outdoor air [l/s-person]	Cooling consumption [GWh/yr]	Total emissions [ktonCO ₂ eq/yr]
Estimated current installed-stock consumption (recirculation, infiltration only)	4.0	1,667	415
Illustrative 7.4 L/s-person ventilation benchmark (2024 edition; current status to be verified)	7.4	2,023	503



Ventilation scenario	Outdoor air [l/s-person]	Cooling consumption [GWh/yr]	Total emissions [ktonCO ₂ eq/yr]
Illustrative enhanced ventilation benchmark (10.3 L/s-person; current status to be verified)	10.3	2,328	579

Intervention logic

The estate divides into two segments that call for different responses. The first comprises schools in hot regions with constrained municipal budgets and, in parts of the North, less reliable power supply. Here the priority is passive: reflective or insulated roofing to cut the dominant transmission load through lightweight fibre-cement roofs, cross-ventilation and ceiling fans, external shading of glazing, and vegetation in school grounds. These measures cost a fraction of mechanical cooling per degree of indoor temperature reduction, remain effective during outages, and their investment case rests on learning outcomes and resilience rather than on energy savings; they are natural candidates for FNDE infrastructure programmes and align with the regressive geography of the deficit, since the hottest networks outside the North are also the least climatised.

The second segment, urban and institutional schools with reliable grid access, is the near-term market for efficient mechanical cooling: inverter hi-wall splits and, in larger buildings, VRF systems, procured under INMETRO label classes A with low-GWP refrigerants such as R-32. Procurement design is the decisive lever in this segment: tenders awarded on lowest purchase price systematically select on/off units whose lifetime electricity cost exceeds the capital saving, so award criteria should weight life-cycle cost, seasonal efficiency (IDRS) and a maintenance plan that limits refrigerant leakage. Aggregated purchasing across municipal networks can compress prices for high-efficiency equipment.

In this second segment, on-site solar generation is a natural complement: the net-metering framework of Lei 14.300/2022 allows schools to offset daytime cooling load with rooftop photovoltaics, whose generation profile coincides with school hours and with the afternoon cooling peak [63], and Brazil already has a large distributed-generation base [21]. Sequencing matters: passive measures first, since they shrink the plant size every subsequent investment must serve; efficient equipment second; generation third.

Quick summary

The key barriers and enablers for sustainable cooling investment in the education sector are summarised in Table 28.

Table 28 – Brazil: education sector cooling quick summary

Dimension	Barriers	Enablers
Technology	Over half of classrooms lack mechanical cooling; lowest-price tenders entrench on/off splits	Inverter splits (EER 3.5–4.2) and VRF; R-32 transition; evaporative cooling in dry zones [19][49]
Economics and procurement	Constrained municipal budgets; awards on purchase price ignore life-cycle cost	Life-cycle and IDRS criteria in tenders; aggregated purchasing; cooling-as-a-service; FNDE and development finance [17]
Regulation	No school-climatisation standard; national cooling plan still in drafting [15]	INMETRO MEPS and labelling in force [11][19]; net metering for school PV under Lei 14.300/2022 [63]
Infrastructure and resilience	Afternoon shifts coincide with peak heat; outages in the North expose schools [16]	Passive envelope measures; rooftop PV matched to the cooling peak; ceiling fans as baseline [63]



Dimension	Barriers	Enablers
Data	Climatisation tracked only through Census microdata; no consumption metering	Censo Escolar microdata [53]; school submetering

Food Cold Chain

Structure: agribusiness exports, maritime reefers and a fragmented domestic chain

Brazil's cold chain is defined by its scale and strong export orientation, but it extends from industrial processing to fragmented domestic distribution [64]. Agribusiness exports reached approximately USD 164 billion in 2024, close to half of Brazilian exports, and meat, poultry, soy, sugar, coffee and fruit are major export flows [65][66][67]. Alongside export-oriented freezing and cold storage, domestic dairy, horticulture, fish and retail-ready food move mainly by road through wholesale markets, supermarket distribution centers and small operators. Brazilian studies and older technical sources report substantial fruit-and-vegetable losses, but estimates vary by commodity, supply-chain stage and method; the 40% value used later is therefore an explicit screening assumption rather than an official current national loss rate [26][27]. The maritime, industrial and domestic segments are contrasted in Table 29.

Table 29 – Brazil: export/logistics vs domestic cold chain

Dimension	Export/maritime segment	Domestic segment
Maturity	Large, capital-intensive, growing	Fragmented; high losses at farm and retail
Key products	Beef, poultry, soy, sugar, coffee and fruit [65][66][67]	Dairy, horticulture, fish, retail-ready food
Logistics	Ports (Santos, Paranaguá/TCP, Itajaí–Navegantes), reefer ships, cabotage [68][69]	Road-dominated; CEASA wholesale hubs; modular cold rooms; retail distribution
Post-harvest losses	driven by logistics and handling	Substantial and highly variable by commodity and stage; no single current national rate is used as an observed value [26][27]
Refrigerants	R-134a moving to R-513A, with CO ₂ (R-744) in newest reefers [49]	Ammonia and CO ₂ in large industrial systems; HFC and hydrocarbon solutions vary by application [13][49][70]

The maritime segment is large and expanding. Brazil's ports handled a record 1.32 billion tonnes of cargo in 2024, and containerized cargo grew strongly [68]. Refrigerated exports are concentrated in specialized corridors. The Paranaguá Container Terminal (TCP) reports 5,268 reefer plugs after its 2024 expansion and describes the yard as the largest in South America [69]. Coastal shipping is being expanded under the BR do Mar program (Lei 14.301/2022), which is intended to increase cabotage capacity [71]. Published reefer-fleet and throughput figures vary by source, so project preparation should prioritize ANTAQ and terminal-authority data over undated trade estimates [68][69].

The industrial side of the cold chain is also significant. Large meat and poultry processors operate blast-freezing and cold-storage capacity at industrial scale. Ammonia (R-717) is a long-established refrigerant for large food-processing and cold-storage plants, while CO₂ (R-744) is used in cascade and transcritical configurations in appropriate applications [70]. These systems are concentrated near production centers and are priority areas for efficiency, heat recovery, leak detection and safe refrigerant management. Under the



screening calculation below, in-plant process refrigeration is the largest quantified electricity load in the selected cold-chain segments.

Export cold chain: key logistics vulnerabilities

Despite the relative maturity of the export segment, several infrastructure bottlenecks introduce systematic cold-chain risks that individual project developers cannot resolve unilaterally but must design around [68]. The domestic distribution chain faces a different set of constraints, including sparse cold storage for horticulture, last-mile gaps and less reliable inland power, which are taken up in the barriers and priorities below. The principal export-side vulnerabilities, their impact on cargo integrity, and the recommended interventions are identified in Table 30.

Table 30 – Brazil: export cold-chain infrastructure bottlenecks [68]

Bottleneck	Impact	Addressable solution
Long interior-to-port road haul (Centre-West to Santos/Paranagua, 1,500-2,000 km) with limited refrigerated rail	Genset reliance, higher transport cost and emissions, temperature-excursion risk	Modal shift to coastal shipping (BR do Mar) and refrigerated rail; reefer telemetry [71]
Congestion at the Port of Santos in peak export season	Extended dwell and peaks in reefer-plug demand	Reefer-plug expansion, off-peak scheduling, diversion to Paranagua/TCP and Itajai-Navegantes [68]
Limited shore power for berthed reefer vessels at several terminals	Auxiliary-engine diesel use and emissions during berthing	Shore power (cold ironing) at reefer berths
Phytosanitary and customs throughput (MAPA / Receita Federal) at peak	Weekend and holiday bottlenecks for perishables	Continuous inspection service at major reefer terminals
Export-heavy meat lanes create reefer repositioning imbalance	Empty-reefer positioning cost	Triangulation and non-operating-reefer (NOR) use on return legs
Reefer fleet and throughput data partly from trade press	Weak basis for capacity planning	Consolidate ANTAQ and port-authority statistics [68]

These bottlenecks are not marginal operational inconveniences. For temperature-sensitive cargo, each gap in the cold chain translates directly into product loss, market rejection, or reduced export value. Project developers should treat infrastructure redundancy and temperature monitoring as non-negotiable design requirements rather than optional enhancements.

Energy footprint of cold chain operations

Cold chain operations generate a significant and growing energy and emissions footprint across all segments. Estimated energy demand and GHG emissions for the main segments of Brazil's cold chain are presented in Table 31.

Table 31 – Brazil: estimated operational cold-chain electricity demand and electricity-related emissions

Segment	Estimated energy demand	Notes
Domestic cold storage (perishables)	89 GWh/yr	16.35 Mt refrigerated domestic perishables; dwell 12 days



Segment	Estimated energy demand	Notes
Export pre-shipment cold storage	95 GWh/yr	10.5 Mt refrigerated exports (meat + fruit); dwell 20 days
Maritime reefers (export)	309 GWh/yr	Export tonnage via TEU; 2.1 kW/TEU over in-country refrigeration period
Industrial process refrigeration (meat)	3,998 GWh/yr	~29 Mt meat throughput; chilling + freezing + plant cold storage; ammonia plants [65][66][70][72][73]
Total cold-chain electricity	4,491 GWh/yr	≈ 0.69% of 2024 final electricity consumption (650.4 TWh) [20]
Operational electricity-related emissions	≈ 0.27 Mt CO ₂ e/yr	4,491 GWh × 0.0599 t CO ₂ e/MWh [20]
Product-loss-associated lifecycle emissions	Not quantified	Requires commodity-, stage- and site-specific evidence; report separately [27][74]

Cold-chain energy estimates cover four components. Maritime reefer consumption is derived from approximately 10.5 Mt/yr of refrigerated exports, converted at 12 tonnes per TEU and 2.1 kW per reefer [65][66]. The resulting 309 GWh/yr corresponds to an assumed in-country energized period of approximately seven days per TEU, covering port dwell and connected inland stages; this is a model assumption that should be replaced by corridor-specific dwell data where available. Cold-storage consumption uses 165 kWh per tonne-year applied to average inventory inferred from dwell time. Export pre-shipment storage is assigned 20 days and domestic perishables 12 days. The domestic flow is an illustrative modeled stream based on production and loss assumptions reported in the cited Brazilian literature [26][27], not an official cold-store inventory.

A fourth and larger component is industrial process refrigeration in meat and poultry plants. It is estimated from approximately 29 Mt of 2024 meat production [65][66] multiplied by refrigeration-specific electricity intensities. A published European meat-industry assessment reports 149 kWh per tonne of hot standard carcass weight for slaughterhouses [72]; this report applies a central modeling assumption that refrigeration accounts for 50% of that electricity, then adds product-specific freezing increments from the comparative meat-processing literature [73]. The resulting screening intensities are about 165 kWh/t for poultry, 99 kWh/t for beef and 121 kWh/t for pork. Because technology, product mix and plant utilization differ between Europe and Brazil, these values are transferable engineering benchmarks rather than measured Brazilian national averages. Dairy, fish, further-processed foods, retail refrigeration and internal refrigerated transport are excluded.

The resulting cold-chain electricity demand is about 4,491 GWh per year. By far the largest component is industrial process refrigeration at the meat and poultry plants, at roughly 4,000 GWh. The logistics and storage of perishables account for the remainder, about 309 GWh for maritime reefers, 95 GWh for export pre-shipment storage and 89 GWh for domestic cold storage.

Operational electricity-related emissions from the quantified cold-chain segments are approximately 0.27 Mt CO₂e per year, using the 2024 average grid factor of 0.0599 t CO₂e/MWh [20]. Product-loss-associated lifecycle emissions are not added to this operational footprint. Their calculation requires commodity-specific production footprints, the stage and cause of loss, and evidence of the share that a proposed cold-chain intervention could avoid [27][74]. Applicants may quantify avoided product losses at project level, but should report them separately from equipment electricity and refrigerant emissions and document the causal baseline.



Market drivers and projections

Several structural forces are converging to drive cold chain market growth in Brazil over the coming decade. The key drivers and their projected impact are summarised in Table 32.

Table 32 – Brazil: food cold chain market drivers [28][69]

Driver	Detail
Export volume growth	Record meat exports (beef 2.89 Mt, poultry 5.29 Mt, pork 1.35 Mt in 2024) [65][66]; reefer handling at record levels, led by frozen meat, with TCP (South America's largest reefer yard, 5,268 plugs) the leading corridor [69]
Modal shift to cabotage	BR do Mar (Lei 14.301/2022) expands coastal-shipping capacity, shifting refrigerated volumes from long-haul road to lower-emission sea freight [71]
Urbanisation-led domestic demand	~87% urban population; rising demand for fresh, retail-ready and processed food expands refrigerated retail and distribution
Climate adaptation	Warming of +1.2 to +2.2 °C by 2050 compresses the harvest-to-spoilage window and widens the addressable market [6]
Projected market value	Cold-chain logistics market ≈ USD 5.64 bn (2026), growing ~4.15%/yr to 2031 [28]

Taken together, these drivers create a demand signal that is both large and durable. The combination of export growth, urbanisation-led domestic consumption, and climate-driven market expansion means that cold chain investment in Brazil is not dependent on any single growth vector, reducing the risk profile for long-term infrastructure commitments.

Barriers and technology priorities

The principal barriers constraining cold chain development in Brazil are identified in Table 33.

Table 33 – Brazil: food cold chain investment barriers

Barrier	Detail
High and uneven post-harvest losses in parts of the domestic chain [26][27]	Reported values vary by commodity, location and supply-chain stage; domestic horticulture remains fragmented and cold storage is concentrated in export-oriented agribusiness
Energy and refrigerant footprint of reefers and ports	Maritime reefers draw ~309 GWh/yr; industrial plants use ammonia and reefers commonly use R-134a, with lower-GWP transition options including R-513A and R-744; under a near-decarbonised grid, refrigerant leakage dominates the energy-related climate impact
Refrigerant transition under Kigali	Decreto 11.666/2023 implements the HFC phase-down. Controlled HFC/HCFC imports are subject to applicable IBAMA procedures; natural refrigerants are instead governed by product- and site-specific safety and conformity requirements [13][14]
Data quality on losses and the reefer fleet	Brazil has not reported to the FAO Food Loss Index; reefer-fleet and throughput figures are partly from trade press and should be consolidated against ANTAQ and EMBRAPA datasets [26][68]

The financing barrier deserves particular attention. At the smallholder end of the market, the constraint is not the absence of suitable technology but the inability to mobilise upfront capital. Interventions that address this through service-based procurement models and cooperative aggregation are likely to achieve greater scale and sustainability than those focused on equipment supply alone.



Technology and intervention priorities

The recommended technology and intervention priorities, organised by axis and target segment, are set out in Table 34.

Table 34 – Brazil: cold chain technology and intervention priorities [13]

Technology/intervention axis	Target segment	Key design requirements
Solar and hybrid modular cold rooms, cooperative aggregation and cooling-as-a-service	Domestic smallholder and horticulture	Off-grid or hybrid PV, low-GWP refrigerants (R-290, R-600a), simple operation and maintenance, output-linked financing
CO ₂ (R-744) and R-513A reefers, shore power and technician training on leak reduction [49]	Export and maritime segment	Low-GWP reefers, cold ironing at reefer berths, leak-tight design and reefer telemetry
Natural-refrigerant industrial systems and controlled-substance compliance [13][14][70]	Meat and poultry processing (industrial)	Ammonia and CO ₂ systems, heat recovery, leak detection and safe end-of-life management; verify IBAMA procedures only for controlled substances
Consolidation of official ANTAQ and EMBRAPA datasets [26][68]	Sector governance and policy	Reefer-fleet registry, food-loss monitoring and cold-store submetering

The two segments identified in Table 29 require distinct intervention logics: the export segment demands precision, compliance, and integration with international cold chain standards, while the domestic segment demands affordability, operational simplicity, and solutions designed for grid-unstable or off-grid deployment.

Quick summary

The key barriers and enablers for sustainable cold chain investment in Brazil are summarised in Table 35.

Table 35 – Brazil: food cold chain quick summary

Dimension	Barriers	Enablers
Energy infrastructure	Electricity tariffs vary by distribution area; diesel reliance persists for long inland reefer haul and gensets [18]	~88% renewable grid and very low grid emission factor (0.0599 tCO ₂ /MWh); abundant solar; cooling-as-a-service [20]
Logistics & port infrastructure	Santos congestion; long interior-to-port road haul; limited refrigerated rail; shore-power gaps	Paranagua/TCP (5,268 reefer plugs) and Itajai-Navegantes; cabotage expansion under BR do Mar [69][71]
Financing & affordability	Upfront capital for domestic and smallholder cold rooms; fragmented demand	Cold-chain market ~USD 5.64 bn (2026) [28]; cooling-as-a-service and development finance
Regulatory & compliance	HFC phase-down requires fleet transition; refrigerant servicing and leakage	Decreto 11.666/2023 (Kigali) and IBAMA quotas [13][14]; national cooling plan in drafting [15]
Market structure	Fragmented domestic chain; food-loss rates vary by product and stage and are not treated as operational cooling emissions [26][27]	Record meat exports [65][66]; record reefer handling led by frozen meat [69]; modal shift to cabotage [71]



References

- [1] IBGE, “PIB cresce 3,4% em 2024 e fecha o ano em R\$ 11,7 trilhões,” Agência IBGE Notícias, 2025. [Online]. Available: <https://agenciadenoticias.ibge.gov.br/agencia-sala-de-imprensa/2013-agencia-de-noticias/releases/42774-pib-cresce-3-4-em-2024-e-fecha-o-ano-em-r-11-7-trilhoes>
- [2] World Bank, “Climate Change Knowledge Portal – Brazil (CMIP6 projections, CDD),” CCKP. [Online]. Available: <https://climateknowledgeportal.worldbank.org/country/brazil>
- [3] C. A. Alvares, J. L. Stape, P. C. Sentelhas, J. L. de Moraes Gonçalves and G. Sparovek, “Köppen’s climate classification map for Brazil,” *Meteorologische Zeitschrift*, vol. 22, no. 6, pp. 711–728, 2013, doi: 10.1127/0941-2948/2013/0507.
- [4] L. C. Dantas et al., “Projections of extreme weather events according to climate change scenarios and populations at-risk in Brazil,” *Climatic Change*, vol. 178, no. 152, 2025, doi: 10.1007/s10584-025-03989-2.
- [5] IBGE, “Estimativas da População 2024,” 2024. [Online]. Available: https://ftp.ibge.gov.br/Estimativas_de_Populacao/Estimativas_2024/estimativa_dou_2024.pdf
- [6] CMCC Foundation, “G20 Climate Risk Atlas – Brazil,” 2021. [Online]. Available: <https://files.cmcc.it/g20climaterisks/Brazil.pdf>
- [7] IBGE, “Censo 2022 – Panorama,” 2023–2024. [Online]. Available: <https://censo2022.ibge.gov.br/panorama/>
- [8] L. W. Bezerra et al., “Impacts of a warmer world on space cooling demand in Brazilian households,” *Energy and Buildings*, 2021, doi: 10.1016/j.enbuild.2020.110696.
- [9] IBGE, “Censo 2022: Favelas e Comunidades Urbanas (2ª edição),” 2024. [Online]. Available: <https://www.ibge.gov.br/geociencias/organizacao-do-territorio/tipologias-do-territorio/15788-favelas-e-comunidades-urbanas.html>
- [10] World Bank, “Access to electricity (% of population) – Brazil,” World Development Indicators. [Online]. Available: <https://data.worldbank.org/indicator/EG.ELC.ACCS.ZS>
- [11] Comitê Gestor de Indicadores e Níveis de Eficiência Energética (CGIEE), Resolução nº 1, de 29 de abril de 2022, “Programa de Metas para Condicionadores de Ar,” 2022. [Online]. Available: <https://www.gov.br/mme/pt-br/assuntos/conselhos-e-comites/cgiee/portarias-e-resolucoes/resolucao-n-01-2022-condicionadores-de-ar.pdf>
- [12] International Energy Agency (IEA), “Electricity generation by source: Brazil,” IEA Data Explorer, 2024.
- [13] MMA / IBAMA, Programa Brasileiro de Eliminação dos HCFCs (PBH), final stage; and IBAMA, Instrução Normativa nº 29/2023 and Montreal Protocol import-control guidance for controlled substances. [Online]. Available: <https://www.gov.br/mma/pt-br/assuntos/noticias/brasil-aprova-ultima-etapa-de-programa-para-eliminacao-de-substancias-destruidoras-da-camada-de-ozonio> ; <https://www.gov.br/ibama/pt-br/assuntos/notas/2023/ibama-publica-instrucao-normativa-sobre-controle-de-importacao-de-substancias-que-provocam-o-aquecimento-global> ; <https://www.gov.br/ibama/pt-br/assuntos/emissoes-e-residuos/emissoes/protocolo-de-montreal>
- [14] Presidência da República, “Decreto nº 11.666, de 24 de agosto de 2023 (Emenda de Kigali),” 2023. [Online]. Available: https://www.planalto.gov.br/ccivil_03/_ato2023-2026/2023/decreto/D11666.htm
- [15] United Nations Brazil / UNEP / Ministério do Meio Ambiente e Mudança do Clima, “Brasil inicia elaboração do Plano Nacional de Ação pelo Resfriamento,” 9 Mar. 2026. [Online]. Available: <https://brasil.un.org/pt-br/311376-brasil-inicia-elabora%C3%A7%C3%A3o-do-plano-nacional-de-a%C3%A7%C3%A3o-pelo-resfriamento-para-enfrentar-o>
- [16] ANEEL, “ANEEL divulga os resultados do desempenho das distribuidoras na continuidade do fornecimento de energia elétrica em 2024,” 2025; and official distribution-service indicators. [Online]. Available: <https://www.gov.br/aneel/pt-br/assuntos/noticias/2025/aneel-divulga-os-resultados-do-desempenho-das-distribuidoras-na-continuidade-do-fornecimento-de-energia-eletrica-em-2024> ; <https://www.gov.br/aneel/pt-br/centrais-de-conteudos/relatorios-e-indicadores/distribuicao>
- [17] Government of Brazil, “Brazil presents its new climate target (Second NDC),” Planalto, 2024. [Online]. Available: <https://www.gov.br/planalto/en/latest-news/2024/11/brazil-presents-its-new-climate-target-aligned-with-mission-1.5oc>



- [18] ANEEL, “Ranking das Tarifas,” official residential B1 tariff database. Values vary by distribution area and the published ranking excludes taxes and other bill components. [Online]. Available: <https://www.gov.br/aneel/pt-br/assuntos/tarifas/ranking-das-tarifas>
- [19] INMETRO, Portaria nº 269, de 22 de junho de 2021, as amended including by Portaria nº 672, de 2025; and “Condicionadores de ar – Tabelas de eficiência energética (PBE/ENCE).” [Online]. Available: https://www.inmetro.gov.br/legislacao/detalhe.asp?seq_ato=2783&seq_classe=1 ; https://www.inmetro.gov.br/legislacao/detalhe.asp?seq_ato=3117&seq_classe=1 ; <https://www.gov.br/inmetro/pt-br/assuntos/regulamentacao/avaliacao-da-conformidade/programa-brasileiro-de-etiquetagem/tabelas-de-eficiencia-energetica/condicionadores-de-ar>
- [20] EPE / MME, “Balanço Energético Nacional 2025 (ano base 2024) – Relatório Síntese,” 2025. [Online]. Available: <https://www.epe.gov.br/pt/publicacoes-dados-abertos/publicacoes/balanco-energetico-nacional-2025>.
- [21] EPE, “Atlas da Eficiência Energética – Brasil 2024,” 2024. [Online]. Available: <https://www.epe.gov.br/sites-pt/publicacoes-dados-abertos/publicacoes/PublicacoesArquivos/publicacao-857/>.
- [22] IBGE, “Biomassas e Sistema Costeiro-Marinho do Brasil,” 2019/2024. [Online]. Available: <https://www.ibge.gov.br/geociencias/informacoes-ambientais/vegetacao/15842-biomassas.html>
- [23] Casa Fluminense and L. Sampaio, “Sem clima para aprender,” ((o))eco, 15 Apr. 2025, drawing on the Casa Fluminense Painel Climático. [Online]. Available: <https://oeco.org.br/colunas/sem-clima-para-aprender/>
- [24] C. Michels, S. Güths, D. L. Marinoski, and R. Lamberts, “Thermal performance and thermal resistance of fibre cement roof tiles: Experimental study,” *Energy and Buildings*, vol. 231, art. 110569, 2021, doi: 10.1016/j.enbuild.2020.110569; and ABNT NBR 15575, residential-building performance requirements.
- [25] SEforALL, “Chilling Prospects 2023 – Regional access to cooling risk,” 2023. [Online]. Available: <https://www.seforall.org/chilling-prospects-access-to-cooling-gaps-2023/regional-risks>.
- [26] EMBRAPA, “Perdas e desperdício de alimentos”; and S. A. Cenci, A. G. Soares, and M. Freire Júnior, *Manual de Perdas Pós-Colheita em Frutos e Hortaliças*, EMBRAPA, 1997. [Online]. Available: <https://www.embrapa.br/en/tema-perdas-e-desperdicio-de-alimentos> ; <https://www.embrapa.br/busca-de-publicacoes/-/publicacao/415584/manual-de-perdas-pos-colheita-em-frutos-e-hortalicas>
- [27] R. N. de Moraes et al., “Causes and prevention practices of food waste in fruit and vegetable supply chains: How is Brazil dealing with these issues?”, *Waste Management*, 2022, doi: 10.1016/j.wasman.2022.10.021. The study supports qualitative analysis of causes and prevention practices, not a single official national loss total.
- [28] Mordor Intelligence, “Brazil Cold Chain Logistics Market,” rev. 2026. [Online]. Available: <https://www.mordorintelligence.com/industry-reports/brazil-cold-chain-logistics-market>
- [29] Climate Policy Initiative / PUC-Rio (CPI/PUC-Rio), “Improving Efficiency for Air Conditioners: The Role of the Manaus Free Trade Zone” (policy brief). [Online]. Available: <https://www.climatepolicyinitiative.org/publication/improving-efficiency-for-air-conditioners-the-role-of-the-manaus-free-trade-zone/>
- [30] ABRAVA, “ABRAVA de Portas Abertas foi um sucesso: setor do frio deve faturar R\$ 41 bi em 2024,” 2024. [Online]. Available: <https://abrava.com.br/abrava-de-portas-abertas-foi-um-sucesso-setor-do-frio-deve-faturar-r-41-bi-em-2024/>
- [31] Presidência da República / Receita Federal / PwC Brazil, Lei nº 10.865/2004 (PIS/COFINS-Importação), TIPI under Decreto nº 11.158/2022, and overview of Brazilian import taxes and ICMS. [Online]. Available: http://www.planalto.gov.br/ccivil_03/_ato2004-2006/2004/lei/110.865compilado.htm ; <https://taxsummaries.pwc.com/brazil/corporate/other-taxes>
- [32] ANVISA, Resolução RDC nº 430, de 8 de outubro de 2020, on good practices for the distribution, storage and transport of medicines; and Resolução RDC nº 34, de 11 de junho de 2014, on good practices in the blood cycle. [Online]. Available: https://www.gov.br/anvisa/en/rules-and-regulations/arquivos/rdc-430_2020.pdf ; <https://www.gov.br/anvisa/pt-br/arquivos-noticias-anvisa/3148json-file-1>
- [33] U.S. Department of Commerce, International Trade Administration, “Brazil – Import Requirements and Documentation” and “Brazil – Import Tariffs,” *Country Commercial Guide*, 2024–2026. [Online]. Available: <https://www.trade.gov/country->



commercial-guides/brazil-import-requirements-and-documentation ; <https://www.trade.gov/country-commercial-guides/brazil-import-tariffs>

- [34] Government of Brazil, Portal Único Siscomex, import systems and DUIMP implementation schedule, 2025–2026. [Online]. Available: <https://www.gov.br/siscomex/pt-br> ; <https://www.gov.br/siscomex/pt-br/programa-portal-unico/cronograma>
- [35] MDIC / CAMEX, “Ex-Tarifário” and Resolução GECEX nº 512/2023, as amended, on temporary import-duty reductions for eligible BK and BIT goods without equivalent national production. [Online]. Available: <https://www.gov.br/mdic/pt-br/assuntos/sdic/ex-tarifario> ; <https://www.gov.br/mdic/pt-br/assuntos/camex/resolucoes/gecex/resolucoes-compiladas/resolucao-gecex-no-512-de-16-agosto-de-2023>
- [36] ANATEL, “Certificação de Produtos,” requirements for certification and homologation of telecommunications products. [Online]. Available: <https://www.gov.br/anatel/pt-br/regulado/certificacao-de-produtos>
- [37] Ministério do Trabalho e Emprego, “Norma Regulamentadora nº 13 (NR-13) – Caldeiras, vasos de pressão, tubulações e tanques metálicos de armazenamento.” [Online]. Available: <https://www.gov.br/trabalho-e-emprego/pt-br/acao-a-informacao/participacao-social/conselhos-e-orgaos-colegiados/comissao-tripartite-partitaria-permanente/normas-regulamentadora/normas-regulamentadoras-vigentes/norma-regulamentadora-no-13-nr-13>
- [38] CONFEA, “Anotação de Responsabilidade Técnica – ART,” professional responsibility under the CONFEA/CREA system. [Online]. Available: <https://www.confea.org.br/servicos-prestados/anotacao-de-responsabilidade-tecnica-art>
- [39] BNDES, “Fundo Clima,” financing for eligible machinery, equipment and investment projects linked to greenhouse-gas reduction and climate adaptation. [Online]. Available: <https://www.bndes.gov.br/wps/portal/site/home/financiamento/produto/fundo-clima>
- [40] A. Padilha, A. Massuda, F. Leônidas, A. Davidian et al., “Thirty-five years of Brazil’s Unified Health System (SUS): from Alma-Ata to the climate challenge,” *Lancet Regional Health – Americas*, vol. 51, 101295, 2025, doi: 10.1016/j.lana.2025.101295. [Online]. Available: [https://www.thelancet.com/journals/lanam/article/PIIS2667-193X\(25\)00306-0/fulltext](https://www.thelancet.com/journals/lanam/article/PIIS2667-193X(25)00306-0/fulltext)
- [41] World Bank, “Hospital beds (per 1,000 people) – Brazil (SH.MED.BEDS.ZS),” World Development Indicators. [Online]. Available: <https://data.worldbank.org/indicator/SH.MED.BEDS.ZS?locations=BR>
- [42] CONASS / DATASUS-CNES, “Leitos hospitalares por mil habitantes,” 2023. [Online]. Available: <https://elasticnes.saude.gov.br/leitos>
- [43] Ministério da Saúde, “Hospitais e Leitos” (open dataset). [Online]. Available: <https://dadosabertos.saude.gov.br/dataset/hospitais-e-leitos>
- [44] Moody’s Local Brasil, “Setor de Saúde no Brasil: Estrutura, Fundamentos e Tendências,” 30 Jan. 2025. [Online]. Available: https://moodylocal.com.br/wp-content/uploads/2025/01/Research_Saude_Estudo-Setorial_jan25.pdf
- [45] A. Szklo et al., “Energy consumption indicators and CHP technical potential in the Brazilian hospital sector,” *Energy Conversion and Management*, vol. 45, no. 13–14, pp. 2075–2091, 2004, doi: 10.1016/j.enconman.2003.10.019.
- [46] Ministério da Saúde, Manual de Rede de Frio do Programa Nacional de Imunizações, 6th ed., Brasília, 2025, ISBN 978-65-5993-918-3. [Online]. Available: <https://www.gov.br/saude/pt-br/centrais-de-conteudo/publicacoes/guias-e-manuais/2025/rede-de-frio-pni.pdf>
- [47] Q. Zhao et al., “Geographic, Demographic, and Temporal Variations in the Association between Heat Exposure and Hospitalization in Brazil: A Nationwide Study between 2000 and 2015,” *Environmental Health Perspectives*, vol. 127, no. 1, 2019, doi: 10.1289/EHP3889.
- [48] ABNT, ABNT NBR 7256:2021, “Tratamento de ar em estabelecimentos assistenciais de saúde (EAS) – Requisitos para projeto e execução das instalações,” including Amendment 1:2022. Current status and project-specific applicability should be checked in the ABNT catalog.
- [49] Selected manufacturer technical documentation on lower-GWP product pathways: Chemours, Opteon XP10 (R-513A) product information; Daikin, R-32 VRV product range; Johnson Controls YORK, YVWA R-134a/R-513A chiller documentation; and Carrier, PrimeLINE container refrigeration specifications. [Online]. Available: <https://www.chemours.com/en/-/media/files/opteon/opteon-xp10-prodinfo.pdf> ; https://www.daikin.eu/en_us/product-



group/vrv/vrv5.html ; <https://docs.johnsoncontrols.com/chillers/v/u/YORK/en-US/YVWA-Style-A-R-134a-and-R-513A-Single-and-Dual-Compressor/825> ; <https://www.carrier.com/us/en/cold-chain/container/units/primeline/technical-specifications/>

- [50] ASHRAE, ANSI/ASHRAE/IES Standard 90.1-2025, Energy Standard for Buildings Except Low-Rise Residential Buildings. Equipment-specific minimum efficiencies depend on type, capacity, condenser conditions and rating metric. [Online]. Available in read-only form through: <https://www.ashrae.org/technical-resources/standards-and-guidelines/read-only-versions-of-ashrae-standards>
- [51] IPCC, Climate Change 2007: The Physical Science Basis, Working Group I Contribution to the Fourth Assessment Report, Table 2.14 (100-year GWPs, including R-32 = 675, R-125 = 3,500 and R-134a = 1,430; blend values calculated from composition). [Online]. Available: https://archive.ipcc.ch/publications_and_data/ar4/wg1/en/ch2s2-10-2.html
- [52] INEP / MEC, “Censo Escolar da Educação Básica 2024 – Notas Estatísticas,” 2025. [Online]. Available: https://download.inep.gov.br/publicacoes/institucionais/estatisticas_e_indicadores/notas_estatisticas_censo_da_educacao_basica_2024.pdf.
- [53] J. Almada et al., Saunas de Aula: climatização de salas de aula nas escolas brasileiras, analysis based on INEP School Census microdata; underlying primary data: INEP, Microdados do Censo Escolar 2024. [Online]. Available: <https://www.gov.br/inep/pt-br/aceso-a-informacao/dados-abertos/microdados/cento-escolar>
- [54] Todos Pela Educação, “Anuário Brasileiro da Educação Básica – Cap. 12 Infraestrutura,” 2024/2025.
- [55] Folha de S.Paulo, “Só 1 em cada 3 salas de aula públicas do Brasil é climatizada,” Feb. 2025. [Online]. Available: <https://www1.folha.uol.com.br/educacao/2025/02/so-1-em-cada-3-salas-de-aula-publicas-do-brasil-e-climatizada.shtml>
- [56] M. S. Geraldi, M. V. Bavaresco, V. Gnecco, E. Ghisi, and M. Fossati, “Impact of Implementing Air-Conditioning Systems on the School Building Stock in Brazil Considering Climate Change Effects: A Bottom-Up Benchmarking,” in Proceedings of Building Simulation 2021, 2021, doi: 10.26868/25222708.2021.30391.
- [57] J. F. Nicolini, A. F. M. Lamberts, et al., “Evaluation of Strategies that Improve the Thermal Comfort and Energy Saving of a Classroom of an Institutional Building in a Tropical Climate,” Building and Environment, vol. 135, pp. 257-268, 2018, doi: 10.1016/j.buildenv.2018.03.017.
- [58] UNEP, “Global Cooling Watch 2025,” 2025. [Online]. Available: <https://www.unep.org/resources/global-cooling-watch-2025>
- [59] IEA, “The Future of Cooling: Opportunities for Energy-Efficient Air Conditioning,” International Energy Agency, Paris, 2018. [Online]. Available: <https://www.iea.org/reports/the-future-of-cooling>
- [60] ABNT, ABNT NBR 16401-3:2024, “Instalações de ar-condicionado – Sistemas centrais e unitários – Parte 3: Qualidade do ar interior.” ABRAVA / ABNT CB-055 announced suspension of the 2024 edition in May 2025; applicants must verify the current status and applicable edition. [Online]. Available: <https://abrava.com.br/abnt-cb055-informa-a-suspensao-da-abnt-nbr-16401-32024-confira-o-comunicado/>
- [61] INEP, “Censo da Educação Superior 2024,” 2025: approximately 10.23 million enrolments, 50.7% in distance learning and 49.3% in-person. [Online]. Available: <https://www.gov.br/inep/pt-br/areas-de-atuacao/pesquisas-estatisticas-e-indicadores/cento-da-educacao-superior/resultados>
- [62] Presidência da República, “Lei nº 9.394/1996 (LDB), art. 24: mínimo de 200 dias letivos.” [Online]. Available: https://www.planalto.gov.br/ccivil_03/leis/19394.htm
- [63] Presidência da República, “Lei nº 14.300, de 6 de janeiro de 2022 (marco legal da geração distribuída),” 2022. [Online]. Available: https://www.planalto.gov.br/ccivil_03/_ato2019-2022/2022/lei/l14300.htm
- [64] C. S. Bresolin, P. S. Schneider, R. Rego and E. P. Bandarra Filho, “Brazilian cold chain panorama,” International Journal of Refrigeration, vol. 90, pp. 145–155, 2018, doi: 10.1016/j.ijrefrig.2018.04.002.
- [65] ABIEC, “Brasil bate recorde nas exportações de carne bovina em 2024,” reporting approximately 2.89 Mt exported in 2024. [Online]. Available: <https://abiec.com.br/brasil-bate-recorde-nas-exportacoes-de-carne-bovina-em-2024/>
- [66] ABPA, Relatório Anual 2025 (2024 production and export data for poultry and pork). [Online]. Available: <https://abpa-br.org/relatorio/2025/>



- [67] Ministério da Agricultura e Pecuária and MDIC, official Brazilian agribusiness trade releases and Comex Stat database; FAO, agricultural trade statistics. [Online]. Available: <https://comexstat.mdic.gov.br/pt/home> ; <https://www.gov.br/agricultura/pt-br/assuntos/noticias/2024/exportacoes-do-agronegocio-brasileiro-batem-recorde-historico-em-julho-com-us-15-44-bilhoes> ; <https://www.fao.org/faostat/en/#data/TCL>
- [68] ANTAQ, “Recorde nos portos: setor aquaviário movimenta mais de 1,32 bilhão de toneladas em 2024,” 2025. [Online]. Available: <https://www.gov.br/antag/pt-br/noticias/2025/recorde-nos-portos-setor-aquaviario-movimenta-mais-de-1-32-bi-de-toneladas-em-2024>
- [69] TCP – Terminal de Contêineres de Paranaguá, “TCP completes expansion of the largest refrigerated container storage yard in South America,” 2024; and TCP reefer-service information. The terminal reports 5,268 reefer plugs after expansion. [Online]. Available: <https://www.tcp.com.br/en/tcp-completes-expansion-of-the-largest-refrigerated-container-storage-yard-in-south-america/> ; <https://www.tcp.com.br/en/reefer/>
- [70] ASHRAE, ASHRAE Handbook – Refrigeration, chapters on ammonia and carbon-dioxide refrigeration systems; and ASHRAE refrigeration technical resources. [Online]. Available: <https://www.ashrae.org/technical-resources/refrigeration>
- [71] Presidência da República, “Lei nº 14.301, de 7 de janeiro de 2022 (Programa BR do Mar),” 2022. [Online]. Available: https://www.planalto.gov.br/ccivil_03/_ato2019-2022/2022/lei/114301.htm
- [72] J. Nunes, P. D. da Silva, L. P. Andrade, L. Domingues and P. D. Gaspar, “Energy assessment of the Portuguese meat industry,” *Energy Efficiency*, vol. 9, pp. 1163–1178, 2016, doi: 10.1007/s12053-015-9414-7.
- [73] C.A. Ramirez, M. Patel, K. Blok, “How much energy to process one pound of meat? A comparison of energy use and specific energy consumption in the meat industry of four European countries”, *Energy* 31 (2006) 2047-2063 (freezing increments: poultry 120-260, pork 115, cattle 80 kWh/t).
- [74] FAO, Food Wastage Footprint: Impacts on Natural Resources – Summary Report, Rome, 2013; and UNEP, Food Waste Index Report 2024. These sources show that lifecycle impacts vary by commodity and supply-chain stage and do not provide a single project-level Brazilian emission factor. [Online]. Available: <https://www.fao.org/4/i3347e/i3347e.pdf> ; <https://www.unep.org/resources/publication/food-waste-index-report-2024>